

Sub Divisional Engineer, W/S & Sanitation Sub Div, Dasuya

E-mail:- sdewss.dasuyapb@yahoo.com

To

The Principal,
Nand Singh Memorial ,
Public School Terkiana.

No 926 Date 25.06.2026

Subject: - Issue of drinking Water, Health and Sanitary Condition Certificate Session 2026-2027


Ref: - Your Application Ref. No. NSM/1630674/SDE/Dasuya/2660/2026 Date :- 19.06.2026

It is pertaining to the subject cited above that the building of Nand Singh Memorial Public School ,Terkiana, has been inspected by this office and certified that water is fit for drinking and the sanitation condition is found quite satisfactory for the year 2026-2027.


Sub Divisional Engineer,
W/S & Sanitation Sub Division,
Dasuya.

25/06/26


Chairman
Nand Singh Memorial
Public School, Terkiana


Principal
Nand Singh Memorial
Public School, Terkiana

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

Nand Singh Memorial Public School
V.P.O. Terkiana, Tehsil, Dasuya, Distt. Hoshiarpur(Pb.)-144214

No.: RWTLHSP/2627/00275 Dated : 09/06/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. NSM/1630674/GEN/2659/2026 Dated: 08/06/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 08/06/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur**



**Chairman
Nand Singh Memorial
Public School, Terkiana**



**Principal
Nand Singh Memorial
Public School, Terkiana**

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com



TC-17758

TEST REPORT

Name & Address of Customer : Nand Singh Memorial Public School V.P.O. Terkiana, Tehsil, Dasuya, Distt. Hoshiarpur (Pb.)-144214		Customer Reference No.	No : NSM/1630674/GEN/2659/2026 Dated : 08/06/2026
		Sample Submitted by	Mr. Harinder Singh
		Date of Sample Receipt	08/06/2026
		Analysis Starting Date	08/06/2026
		Analysis completion Date	09/06/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC177582600000150F	Sample Type :	Water
Test Report No.:	RWTLHSP/2627/00275	Date of Issue :	09/06/2026
Registration no.:	RWTLHSP/REG2627/01026	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Nand Singh Memorial Public School (Submersible Water) / NA
Village :	TERKIANA	Habitation :	TERKIANA
Block:	Dasuya	District :	Hoshiarpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.27@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	155.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	129.28	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	98.0	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	17.28	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	13.34	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	12.17	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
Hoshiarpur

Harinder Singh

Chairman
Nand Singh Memorial
Public School, Terkiana

End of the Test Report

Principal
Nand Singh Memorial
Public School, Terkiana

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com



TC-17768

TEST REPORT

Name & Address of Customer : Nand Singh Memorial Public School V.P.O. Terkiana, Tehsil, Dasuya, Distt. Hoshiarpur (Pb.)-144214			Customer Reference No.		No : NSM/1630674/GEN/2659/2026 Dated : 08/06/2026	
			Sample Submitted by		Mr. Harinder Singh	
			Date of Sample Receipt		08/06/2026	
			Analysis Starting Date		08/06/2026	
			Analysis completion Date		09/06/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC177582600000150F		Sample Type :		Water	
Test Report No.:	RWTLHSP/2627/00275		Date of Issue :		09/06/2026	
Registration no.:	RWTLHSP/REG2627/01027		Condition of Sample :		Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Transparent Plastic Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Nand Singh Memorial Public School (Filter Water) / NA	
Village :	TERKIANA		Habitation :		TERKIANA	
Block:	Dasuya		District :		Hoshiarpur	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.21@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	113.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	92.92	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	74.48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	15.71	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	8.57	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	10.14	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

Harinder Singh
Chairman

Nand Singh Memorial
Public School, Terkiana

End of the Test Report

Principal
Principal
Nand Singh Memorial
Public School, Terkiana